



Load Short Form
Entire House
Air Comfort Designs

Job:
 Date: Sep 16, 2009
 By: CAD

PO Box 113, Altoona, PA 16603 Phone: 814 946-1860 Fax: 814 946-0151 Email: designer@aircomfortdesigns.com Web: www.aircomfortdesigns.com

Project Information

For: Radiant Example

Design Information

	Htg	Clg		Infiltration
Outside db (°F)	0	88	Method	Simplified
Inside db (°F)	70	75	Construction quality	Semi-tight
Design TD (°F)	70	13	Fireplaces	0
Daily range	-	M		
Inside humidity (%)	30	50		
Moisture difference (gr/lb)	30	30		

HEATING EQUIPMENT

Make	Generic
Trade	
Model	AFUE 92
GAMA ID	
Efficiency	92 AFUE
Heating input	18633 Btuh
Heating output	17142 Btuh
Temperature rise	0 °F
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	

COOLING EQUIPMENT

Make	n/a
Trade	n/a
Cond	n/a
Coil	n/a
ARI ref no.	n/a
Efficiency	n/a
Sensible cooling	0 Btuh
Latent cooling	0 Btuh
Total cooling	0 Btuh
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.40

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Living	300	4617	0	0	0
Dining	140	2026	0	0	0
Kitchen	138	1915	0	0	0
PR	24	0	0	0	0
Master Bedroom	120	2129	0	0	0
Bath	42	126	0	0	0
Hall	43	0	0	0	0
MB Cl	14	0	0	0	0
Mud	28	798	0	0	0
L Cl	8	0	0	0	0
L Cl	8	0	0	0	0
B1 Cl	11	0	0	0	0
Bedroom 1	115	1849	0	0	0

Bold/italic values have been manually overridden

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 7.1.09 RSU02315

2009-Nov-25 17:25:14

C:\Documents and Settings\Owner\Desktop\New Website Examples 111809\New Radiant Example 111909.rup

Page 1

Entire House	991	13461	0	0	0
Other equip loads		3730	389		
Equip. @ 0.93 RSM			360		
Latent cooling			582		
TOTALS	991	17191	942	0	0

Bold/italic values have been manually overridden

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.



Building Analysis Entire House Air Comfort Designs

Job:
Date: Sep 16, 2009
By: CAD

PO Box 113, Altoona, PA 16603 Phone: 814 946-1860 Fax: 814 946-0151 Email: designer@aircomfortdesigns.com Web: www.aircomfortdesigns.com

Project Information

For: Radiant Example

Design Conditions

Location:

Youngstown, OH, US
Elevation: 1184 ft
Latitude: 41°N

Outdoor:

Dry bulb (°F)
Daily range (°F)
Wet bulb (°F)
Wind speed (mph)

Heating

0
-
-
15.0

Cooling

88
21 (M)
72
7.5

Indoor:

Indoor temperature (°F)
Design TD (°F)
Relative humidity (%)
Moisture difference (gr/lb)

Heating

70
70
30
29.6

Cooling

75
13
50
30.3


Infiltration:

Method
Construction quality
Fireplaces

Simplified
Semi-tight
0

Heating

Component	Btuh/ft²	Btuh	% of load
Walls	3.6	3543	20.6
Glazing	32.9	4365	25.4
Doors	11.9	500	2.9
Ceilings	1.8	1804	10.5
Floors	0.2	228	1.3
Infiltration	2.6	3022	17.6
Ducts		0	0
Piping		1552	9.0
Humidification		0	0
Ventilation		2177	12.7
Adjustments		-0	
Total		17191	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	0	0	0
Glazing	0	0	0
Doors	0	0	0
Ceilings	0	0	0
Floors	0	0	0
Infiltration	0	0	0
Ducts		0	0
Ventilation		389	100.0
Internal gains		0	0
Blower		0	0
Adjustments		0	
Total		389	100.0

Overall U-value = 0.048 Btuh/ft²-°F

Data entries checked.

Bold/italic values have been manually overridden



wrightsoft

Right-Suite® Universal 7.1.09 RSU02315

C:\Documents and Settings\Owner\Desktop\New Website Examples 111809\New Radiant Example 111909.rup

2009-Nov-25 17:25:14

Page 1



Component Constructions
Entire House
 Air Comfort Designs

Job:
 Date: Sep 16, 2009
 By: CAD

PO Box 113, Altoona, PA 16603 Phone: 814 946-1860 Fax: 814 946-0151 Email: designer@aircomfortdesigns.com Web: www.aircomfortdesigns.com

Project Information

For: Radiant Example

Design Conditions

Location:		Indoor:		Heating	Cooling
Youngstown, OH, US		Indoor temperature (°F)		70	75
Elevation: 1184 ft		Design TD (°F)		70	13
Latitude: 41°N		Relative humidity (%)		30	50
		Moisture difference (gr/lb)		29.6	30.3
Outdoor:	Heating	Cooling	Infiltration:		
Dry bulb (°F)	0	88	Method		
Daily range (°F)	-	21 (M)	Construction quality		
Wet bulb (°F)	-	72	Simplified		
Wind speed (mph)	15.0	7.5	Semi-tight		
			Fireplaces		
			0		

Construction descriptions

	Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls								
12E-5sw: Frm wall, vnl ext, r-19 cav ins, 1/2" gypsum board int fnsh,								
r-5 ext bd ins, 2"x6" wood frm								
	n	314	0.052	24.0	3.64	1143	0	0
	e	170	0.052	24.0	3.64	620	0	0
	s	322	0.052	24.0	3.64	1172	0	0
	w	167	0.052	24.0	3.64	608	0	0
	all	973	0.052	24.0	3.64	3543	0	0
Partitions								
(none)								
Windows								
4A5-2ov: 2 glazing, clr low-e outr, air gas, insulated vinyl frm mat, clr								
innr, 1/4" gap, 1/8" thk								
	n	20	0.470	0	32.9	658	0	0
	e	49	0.470	0	32.9	1601	0	0
	s	12	0.470	0	32.9	395	0	0
	w	52	0.470	0	32.9	1711	0	0
	all	133	0.470	0	32.9	4365	0	0
Doors								
11Q0: Door, mtl pur core type, mtl strm strm								
	e	21	0.170	10.5	11.9	250	0	0
	w	21	0.170	10.5	11.9	250	0	0
	all	42	0.170	10.5	11.9	500	0	0
Ceilings								
16B-38ad: Attic ceiling, asphalt shingles roof mat, r-38 ceil ins, 1/2"								
gypsum board int fnsh								
		991	0.026	38.0	1.82	1804	0	0
Floors								
19A-19bscp: Part floor, carpet flr fnsh, r-19 ins, frm flr, 10" thkns								
		28	0.049	19.0	2.69	75	0	0
19A-19bstp: Part floor, tile flr fnsh, r-19 ins, frm flr, 10" thkns								
		40	0.049	19.0	2.69	107	0	0
19C-19cscp: Flr floor, frm flr, 6" thkns, carpet flr fnsh, r-2 ext ins, r-19								
cav ins, tight crwl ovr, r-11 wall insul								
		39	0.049	30.0	1.19	46	0	0
43A0: Radiant panel over room, 3/4" ply subflr, staple up T-Fin heat								
xfer plates								
		888	0	0	0	0	0	0







Project Summary
Entire House
Air Comfort Designs

Job:
 Date: Sep 16, 2009
 By: CAD

PO Box 113, Altoona, PA 16603 Phone: 814 946-1860 Fax: 814 946-0151 Email: designer@aircomfortdesigns.com Web: www.aircomfortdesigns.com

Project Information

For: Radiant Example

Notes:

Design Information

Weather: Youngstown, OH, US

Winter Design Conditions

Outside db 0 °F
 Inside db 70 °F
 Design TD 70 °F

Summer Design Conditions

Outside db 88 °F
 Inside db 75 °F
 Design TD 13 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 30 gr/lb

Heating Summary

Structure 13461 Btuh
 Ducts 0 Btuh
 Central vent (30 cfm) 2177 Btuh
 Humidification 0 Btuh
 Piping 1552 Btuh
 Equipment load 17191 Btuh

Sensible Cooling Equipment Load Sizing

Structure 0 Btuh
 Ducts 0 Btuh
 Central vent (30 cfm) 389 Btuh
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 0.93
 Equipment sensible load 360 Btuh

Infiltration

Method Simplified
 Construction quality Semi-tight
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	991	0
Volume (ft ³)	7929	0
Air changes/hour	0.31	0.22
Equiv. AVF (cfm)	41	0

Latent Cooling Equipment Load Sizing

Structure 0 Btuh
 Ducts 0 Btuh
 Central vent (30 cfm) 582 Btuh
 Equipment latent load 582 Btuh
 Equipment total load 942 Btuh
 Req. total capacity at 0.70 SHR 0.0 ton

Heating Equipment Summary

Make Generic
 Trade
 Model AFUE 92
 GAMA ID
 Efficiency 92 AFUE
 Heating input 18633 Btuh
 Heating output 17142 Btuh
 Temperature rise 0 °F
 Actual air flow 0 cfm
 Air flow factor 0 cfm/Btuh
 Static pressure 0.50 in H2O
 Space thermostat

Cooling Equipment Summary

Make n/a
 Trade n/a
 Cond n/a
 Coil n/a
 ARI ref no. n/a
 Efficiency n/a
 Sensible cooling 0 Btuh
 Latent cooling 0 Btuh
 Total cooling 0 Btuh
 Actual air flow 0 cfm
 Air flow factor 0 cfm/Btuh
 Static pressure 0.50 in H2O
 Load sensible heat ratio 0.40

Bold/italic values have been manually overridden

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.





Radiant Heating Tubing Requirements

Job:
Date: Sep 16, 2009
By: CAD

Air Comfort Designs

PO Box 113, Altoona, PA 16603 Phone: 814 946-1860 Fax: 814 946-0151 Email: designer@aircomfortdesigns.com Web: www.aircomfortdesigns.com

Project Information

For: Radiant Example

Tubing Requirements

Roll 1: 600 ft 1/2" BPEX (Part # WX-BP4-600)	5 lengths 3 ft waste	
Mud: 59 ft	Hall: 68 ft	Bath: 76 ft
Bedroom 1: 201 ft	Master Bedroom: 191 ft	
Roll 2: 600 ft 1/2" BPEX (Part # WX-BP4-600)	2 lengths 229 ft waste	
Kitchen: 165 ft	Dining: 205 ft	
Roll 3: 600 ft 1/2" BPEX (Part # WX-BP4-600)	2 lengths 137 ft waste	
Living-A: 232 ft	Living-B: 231 ft	



Radiant Heating Design Summary

Job:
Date: Sep 16, 2009
By: CAD

Air Comfort Designs

PO Box 113, Altoona, PA 16603 Phone: 814 946-1860 Fax: 814 946-0151 Email: designer@aircomfortdesigns.com Web: www.aircomfortdesigns.com

Project Information

For: Radiant Example

Design Information

Total floor area:	991 ft ²	Design temperature:	0 °F
Radiantly heated area:	926 ft ²	Maximum supply temperature:	132 °F
Total panel area:	888 ft ²	Total flow rate:	2.18 gpm
Total tubing area:	874 ft ²	Maximum head loss:	5.09 ft H ₂ O
Total room load:	13461 Btuh	Total tubing required:	1431 ft
Total panel output:	13409 Btuh	Zones 1, Loops 9, Manifolds 1, Actuators 0, Zone Pumps 0, System Pumps 1, Mixing Valves 1, Injection Pumps 0	
Total supplemental heat:	0 Btuh		
Total back loss:	1552 Btuh		
Boiler output required:	14961 Btuh		

Space Heating Information

Room name	Room area (ft ²)	Air temp (°F)	Room load (Btuh)	Supp. heat (Btuh)	F/C	Panel area (ft ²)	Tubing area (ft ²)	Surf. temp. (°F)	Deliv. temp. (°F)	Panel output (Btuh /ft ²)	Back loss (Btuh /ft ²)
Living	300	70	4617	0	F	290	287	79	132	15.9	1.8
Dining	140	70	2026	0	F	136	134	79	132	14.9	1.7
Kitchen	138	70	1915	0	F	115	113	80	132	16.7	1.9
PR	24	70	0	0							
Master Bedroom	120	70	2129	0	F	120	118	80	132	17.7	2.1
Bath	42	70	126	0	F	42	41	71	132	3.0	0.3
Hall	43	70	0	0	F	43	42	70	132	0.0	0.0
MB Cl	14	70	0	0							
Mud	28	70	798	53	F	28	27	85	132	26.5	3.1
L Cl	8	70	0	0							
L Cl	8	70	0	0							
B1 Cl	11	70	0	0							
Bedroom 1	115	70	1849	0	F	115	113	79	132	16.1	1.9
Totals	991		13461	0		888	874				

Hydronic Devices

Device Name	Device type	Load (Btuh)	Flow (gpm)	Head (ft H ₂ O)	S/R tubing or Size,Cv	SWT Req. (°F)	SWT Spld (°F)
Manifold1	Manifold	14961	2.2	5.09	3/4" BPEX	132	132
MixDevice1	Tempering valve	14961	2.2	0		132	132
SysPump1	System Pump	14961	2.2	4.98	3/4" COPPER	132	132
PrimPump1	Primary Pump	14961	1.6	0	3/4" COPPER	180	180

Hydronic Navigator Tree

